



# The 20% Wind Energy Scenario: System Operation and Transmission Needs

---

2008 IEEE PES Meeting

Pittsburgh, PA

July 22, 2008

8:00 am – noon



J. Charles Smith  
Executive Director  
UWIG

## What is UWIG?

---


- ◆ Non-profit corporation established by 6 utilities in 1989 with support from EPRI and DOE/NREL
- ◆ Current membership in excess of 120, including utilities, developers, manufacturers, consultants, government organizations
- ◆ Focus on technical issues
- ◆ Mission: To accelerate the development and application of good engineering and operational practices supporting the appropriate integration of wind power into the electric system

## Outline of Topics

---

- ◆ Lessons from Recent Studies and Experience Dealing With High Wind Penetration
- ◆ Transmission Issues
- ◆ Recommendations
- ◆ Conclusions


# 20% Wind Energy Can Be Managed



Wind integration costs for three penetration levels and pattern years.  
Cost of incremental operating reserves is embedded.

Source:  
MN DOC

# Time Scales of Interest



## Summary of Wind Plant Ancillary Service Costs

### Ancillary Services Cost Comparison

Date	Study	Wind Capacity Penetration (%)	Regulation Cost (\$/MWh)	Load Following Cost (\$/MWh)	Unit Commitment Cost (\$/MWh)	Gas Supply Cost (\$/MWh)	Total Operating Cost Impact (\$/MWh)
May 03	Xcel-UWIG	3.5	0	0.41	1.44	na	1.85
Sep 04	Xcel-MNDOC	15	0.23	na	4.37	na	4.60
Dec 06	MN/MNDOC	33	na	na	na	na	4.41
July 04	CA RPS Multi-year Analysis	4	0.45	na	na	na	na
June 03	We Energies	4	1.12	0.09	0.69	na	1.90
June 03	We Energies	29	1.02	0.15	1.75	na	2.92
2005	PacifiCorp	20	0	1.6	3.0	na	4.6
April 06	Xcel-PSCo	10	0.20	na	2.26	1.26	3.72
April 06	Xcel-PSCo	15	0.20	na	3.32	1.45	4.97




# Some Additional Reserves May Need to be Committed

Reserve Category	Base		15% Wind		20% Wind		25% Wind	
	MW	%	MW	%	MW	%	MW	%
Regulating	137	0.65%	149	0.71%	153	0.73%	157	0.75%
Spinning	330	1.57%	330	1.57%	330	1.57%	330	1.57%
Non-Spin	330	1.57%	330	1.57%	330	1.57%	330	1.57%
Load Following	100	0.48%	110	0.52%	114	0.54%	124	0.59%
Operating Reserve Margin	152	0.73%	310	1.48%	408	1.94%	538	2.56%
<b>Total Operating Reserves</b>	<b>1049</b>	<b>5.00%</b>	<b>1229</b>	<b>5.86%</b>	<b>1335</b>	<b>6.36%</b>	<b>1479</b>	<b>7.05%</b>


Estimated Operating Reserve Requirement for  
MN BAs – 2020 Load

Source:  
MN DOC  
**IEEE July '08 -- 7**

# Increased Balancing Cost



# Forecasting and Balancing Markets Reduce Impacts



## Different Forecasts for Different Time Periods

---

- ◆ Situational awareness forecast: used for severe weather events (real-time)
- ◆ Hour ahead forecast: uses rapid update cycle to produce 10 min forecasts 4-6 hrs ahead, updated every hour
- ◆ Day ahead forecast: Hourly forecasts 2-4 days ahead, updated every 12 hours, uses national weather service models
- ◆ Nodal forecast: hourly forecast of transmission system nodal injections for managing transmission congestion
- ◆ Different performance metrics for different forecasts



## How Good is the Forecast?

- ◆ Wind plant output can be forecast within some margin of error, and forecasts are getting better

### Forecast Error


	<u>Single Plant</u>	<u>Large Region</u>
<u>Hour Ahead</u>		
Energy (% actual)	10-15%	6-11%
Capacity (% rated)	4-6%	3-6%
<u>Day Ahead</u>		
Hourly Energy (% Actual)	25-30%	15-18%
Hourly Capacity (% Rated)	10-12%	6-8%

## Error Decreases with Region Size




- ◆ Error decreases with increase of region size
- ◆ Regional smoothing depends only on region's size, not on number of sites
- ◆ Error is reduced in Germany to 42 % compared to single forecast

# ERCOT Wind Generation – Feb. 26, 2008




Source: ERCOT


# ISOs/RTOs in North America



# An Energy Resource in a Capacity World



# Large Balancing Areas Reduce Reserve Requirements



Approximate regulating requirements for a BA  
as a function of peak demand.

Source:  
MN DOC



# A Comparison of Regulating Reserves

<i>Balancing Authority</i>	<i>Peak Load</i>	<i>Regulating Requirement (from chart)</i>	<i>Regulating Requirement (% of peak)</i>
GRE	3443 MW	56 MW	1.617%
MP	2564 MW	48 MW	1.874%
NSP	12091 MW	104 MW	0.863%
OTP	2886 MW	51 MW	1.766%
Sum of Regulating Capacity		<b>259 MW</b>	
Combined	20984 MW	<b>137 MW</b>	<b>0.655%</b>

Estimated Regulating Requirements for MN BAs - 2020

Source:  
MN DOC

## What About Energy Storage?

---

- ◆ Valuable component of a power system, can provide many benefits
- ◆ Greatest value when operated for benefit of entire system, not dedicated to a single resource
- ◆ One of many sources of flexibility available to the system
- ◆ Expensive, and benefits accrue to different parties, i.e. generation owner, trans. system operator, power marketer
- ◆ Seldom sufficient value in revenue stream for any single party to justify the investment
- ◆ Integration studies do not show need for storage at 20% wind except possibly on small, isolated systems

## Current Transmission Situation

---


- ◆ Current system maintained at minimum level necessary to meet reliability criteria
- ◆ System is reliable, but heavily stressed
- ◆ System is congested for energy market purposes and inter-regional energy transfers
- ◆ System not designed to operate with energy markets or large energy resources like wind
- ◆ Results in high-cost load pockets and low-cost generation pockets, with economical energy transfers limited by transmission congestion

## Evolving Transmission Situation

---

- ◆ Recent studies indicate an opportunity to significantly expand the transmission system to serve both the energy markets and wind generation potential
  - MTEP 06, MTEP 08
  - Joint Coordinated System Plan (JCSP)
  - DOE 20% by 2030
- ◆ DOE 20% scenario stimulated conceptual 765 kV EHV overlay examined by AEP
  - Investment of \$60 billion over next 20 years for 19,000 mi of line to deliver additional 200-400 GW
  - Current transmission investment \$8 billion/yr and growing
- ◆ Building an inter-regional high voltage overlay to address the needs identified in recent studies is unprecedented
- ◆ No previous investigation or understanding established through business models, energy policy, or federal or state policy or regulation

# JCSP Study Regions



Source:  
MISO




# What's Driving Transmission Planning for Wind Energy

---

- ◆ Total potential congestion for the Eastern Interconnection from MTEP '08 20% Renewable Scenario- \$24B/yr in 2021\$
  - Reduction of only about half will be achievable
  - Requires high power transfer capability, low delivery cost with multiple lines self-providing for contingencies
- ◆ Transmission planning must take place on a broad regional basis- link lowest cost areas to highest priced areas
- ◆ Economies of scale in transmission necessary to realize the benefits
- ◆ Revenue from energy transactions pays for the cost of the line
- ◆ Techniques pioneered in MISO Transmission Expansion Plan (MTEP) and JCSP (20% wind energy in Eastern Interconnection)

# Full Constrained Case Annual Load Weighted LMP



Source: MISO

## Example of Opportunity

---

- ◆ With significant wind under RPS policy:
  - A three line 800 kV HVDC and 765 kV AC overlay system appears to have the potential for a 15,000 MW delivery system for energy from the wind areas in western MISO to the east coast for about \$30/MWH
  - The average cost of this energy is about \$65/MWH including losses
  - The delivered cost of energy would then be about \$95/MWH
  - This is less than the \$110/MWH or higher price on much of the east coast
- ◆ Planning techniques pioneered in MISO Transmission Expansion Plan (MTEP) and JCSP

# System Planning and Operation Recommendations

---

- ◆ Perform detailed wind integration studies
- ◆ Deploy more flexible generation and load technologies
- ◆ Improve wind plant output forecasting tools
- ◆ Improve grid codes and wind plant models
- ◆ Aggregate wind plant output over large regions
- ◆ Improve balancing area consolidation and ACE sharing
- ◆ Ongoing forums to share operating experience

# Transmission Planning Recommendations

---

- ◆ Develop adequate transmission capacity through planning process for energy resources
- ◆ Comprehensive regional planning processes
- ◆ Federal leadership in developing high-voltage transmission in support of national energy policy
- ◆ Reassessment of transmission financing approach
  - Customers in remote regions can't afford it
  - load pays in the end
- ◆ More certainty of transmission cost recovery
- ◆ More robust and flexible “smart” grid

## Market Operation and Transmission Policy Recommendations

---

- ◆ Develop well-functioning real-time, hour-ahead and day-ahead energy and price responsive load markets and expand access to those markets
- ◆ Adopt market rules and tariff provisions that are more appropriate to weather-driven resources
- ◆ Make better use of physically (in contrast with contractually) available transmission capacity
- ◆ Eliminate pancaked rates

## and the conclusion is...

---

- ◆ There are no fundamental technical barriers to the integration of 20% wind energy into the nation's electrical system, but...
- ◆ There needs to be a continuing evolution of transmission planning and system operation policy and market development for this to be achieved.

## For More Information

---

- ◆ Visit [www.uwig.org](http://www.uwig.org)
- ◆ Email [info@uwig.org](mailto:info@uwig.org)
- ◆ Phone
  - Charlie Smith 703-860-5160
  - Sandy Smith 865-218-4600
- ◆ Mail
  - Utility Wind Integration Group
  - PO Box 2787
  - Reston, VA 20195 USA

